


← Protok vode m_w (m^3/h)

Primjer:
 Protok vode $28 m^3/h$
 Temperatura ulazne vode $T_{w1} 32^\circ C$
 Temperatura izlazne vode $T_{w2} 24^\circ C$
 Temperaturna razlika $8 K$
 Temperatura vlažnog termometra $T_i 18^\circ C$
 Izbabrani rashladni toranj $2/06$



ESOTEHNA d.o.o. Dijagram za odabir tipa i veličine rashladnog tornja tipa HSA
 Bobovje 52 b
 49 000 Krapina

Rashladni toranj
 HSA 03 ÷ 4

